

LEGEND

- ① CORPORATION STOP – AWWA INLET, COMPRESSION OUTLET FOR VALLCORP TYPE FB 1000.
- ② CURB (SERVICE STOP) – COMPRESSION INLETS & OUTLETS FORD BALL VALVE B44.
1-1/2" & 2: CURB STOPS TO BE FURNISHED WITH 2: GV OPERATING UNIT.
- ③ CURB BOX – EXTENSION TYPE, ARCH PATTERN BASE, 1-1/4" UPPER SECTION, BRASS-PLUG LID. FORD MODEL EA-S OR APPROVED EQUAL.
CURB STOPS GREATER THAN 1: IN SIZE REQUIRE A CURB BOX BASE FORD CB-7.


MAXIMUM SIZE OF DIRECT SERVICE TAP

NOMINAL PIPE SIZE OF MAIN INCHES	MAX. TAP SIZE INCHES
4	3/4
6	1
8	1
10	1-1/2
12	2

TAP SIZES GREATER THAN THOSE SHOWN SHALL BE MADE USING A TAPPED SERVICE SADDLE, SOUBLE BAND STAINLESS STEEL, FORD STYLE 202S, OR APPROVED EQUAL.

TAPS GREATER THAN 2-IN. SIZE SHALL BE MADE WITH A TAPPING SLEVE AND TAPPING VALVE.

NOTE: WORK BY VILLAGE FORCES SHALL INCLUDE ALL WORK FROM THE MAIN UP TO AND INCLUDING THE CURB (SERVICE) STOP AND BOX. WORK BEHIND THE SERVICE STOP, INCLUDING CONNECTING THERETO, IS THE RESPONSIBILITY OF THE PROPERTY OWNER.



VILLAGE OF INDIAN HILL
DEPARTMENT OF WATER WORKS

APPROVED *Jim C. [Signature]*
DATE October 2006

**STANDARD SERVICE
LINES 2 IN. & UNDER**

DRAWING NO.

WW-131