


PLAN VIEW

GENERAL NOTES:

1. FOR PIT CONSTRUCTION DETAILS, SEE STANDARD DRAWING WW-110
2. SERVICE LINE PIPING SHALL BE FLANGED DUCTILE IRON CONFORMING TO VILLAGE OF INDIAN HILL SPECIFICATIONS.
3. DETECTOR CHECK ASSEMBLY PIPING SHALL BE COPPER WITH SCREWED OR SOLDERED BRONZE FITTINGS AND APPURTENANCES
4. METER AND VALVE SUPPORTS MAY BE SOILD BRICK OR BLOCK OR ANY COMMERICAL TYPE APPROVED BY THE WATER WORKS SUPERINTENDENT
5. SHOP DRAWINGS OF THE PROPSED INSTALLATION SHALL BE SUBMITTED TO THE WATER WORKS SUPERINTENDENT PRIOR TO FABRICATION. SHOP DRAWINGS SHALL INCLUDE MAKES, MODELS, AND DETAILS OR THE PROPOSED COMPONENTS.
6. PREFABRICATED ASSEMBLIES MAY BE USED WHEN SPECIFICALLY APPROVED BY THE WATER WORKS SUPERINTENDENT.



VILLAGE OF INDIAN HILL
DEPARTMENT OF WATER WORKS

APPROVED *Jim C. King*
DATE October 2006

STANDARD DETECTOR
CHECK ASSEMBLY

DRAWING NO.

WW-143