



PLAN VIEW

GENERAL NOTES:

1. FOR PIT CONSTRUCTION DETAILS, SEE STANDARD DRAWINGS WW-135 AND WW-136.
2. SERVICE LINE PIPING SHALL BE FLANGED DUCTILE IRON CONFORMING TO VILLAGE OF INDIAN HILL SPECIFICATIONS.
3. DOUBLE DETECTOR CHECK ASSEMBLY PIPING SHALL BE COPPER WITH SCREWED FITTINGS AND APPURTENANCES
4. METER AND VALVE SUPPORTS MAY BE SOILD BRICK OR BLOCK OR ANY COMMERICAL TYPE APPROVED BY THE WATER WORKS SUPERINTENDENT
5. SHOP DRAWINGS OF THE PROPSED INSTALLATION SHALL BE SUBMITTED TO THE WATER WORKS SUPERINTENDENT PRIOR TO FABRICATION. SHOP DRAWINGS SHALL INCLUDE MAKES, MODELS, AND DETAILS OR THE PROPOSED COMPONENTS.
6. PREFABRICATED ASSEMBLIES MAY BE USED WHEN SPECIFICALLY APPROVED BY THE WATER WORKS SUPERINTENDENT.



VILLAGE OF INDIAN HILL
DEPARTMENT OF WATER WORKS

APPROVED *[Signature]*
DATE November 2011

**STANDARD DOUBLE
DETECTOR CHECK
ASSEMBLY**

DRAWING NO.

WW-143